

INSTALLING A SINGLE BOILER

S
E
T
T
I
N
G
U
P

SECONDARY REGULATOR
NOT SUPPLIED

WITHOUT EXTERNAL
SECONDARY REGULATOR

QAC 34:
External probe and/or
QAA 73:
Ambient thermoresistor

The water logic leaving the boiler is managed directly by the LMU from the ambient or external temperature information provided to it.

WITH THE SECONDARY
EXTERNAL REGULATOR(S)

COMMUNICATING
0-10V, 4-20 mA or LPB

**OCI 420 (LPB) or
AGU 2.511 (0-10V) or
AU 2.513 (4-20mA)**

The water logics for secondary distributors are managed by the regulators in place. They transmit the required temperature information to the LMU.

NON-COMMUNICATING

QAC 34 External sensor

The water logics for secondary distributors are managed by the regulators in place. They transmit the required temperature information to the LMU.

SECONDARY
REGULATOR(S)
SUPPLIED

**AGU 2.500 and/or
RVS 46 Kit + OCI 420
Or RVS 63 Kit + OCI 420**